



PERMIT SUBMITTAL CHECKLIST
NFPA 17A & 96 ALTERNATIVE EXTINGUISHING SYSTEMS FOR COMMERCIAL
COOKING/KITCHENS

CONTRACTOR INFORMATION:

- ✓ The designer and applicant contact information must be included in the submittal.
- ✓ The installing contractor must provide a current manufacturer's certification of training for the system type being installed or modified, i.e., ANSUL, Pyro-Chem, Badger, Kidde, etc.

CODE INFORMATION:

- ✓ The most current edition of NFPA 17A and NFPA 96 must be indicated.
- ✓ The installation type must be indicated: new installation or modification to an existing system.
- ✓ Information must be provided which indicates the scope of work proposed.
- ✓ The size of the system is provided relative to the coverage required.

PLANS:

- ✓ Graphically indicates the location of all appliances, the hood(s), and the suppression system(s).
- ✓ Graphically indicates the location of Class K-type portable fire extinguisher(s) and pull station(s).
- ✓ Graphically shows a side view of the kitchen appliance layout, nozzle coverage, and the hood above.
- ✓ The plans are drawn by a or stamped by a qualified kitchen system designer or the manufacturer.

MATERIAL SUBMITTALS:

- ✓ Data sheets and manufacturer's information **MUST** be provided and clearly highlighted for all system components and appliances being used.

See the most current version NFPA 17A, Chapter 6 Plans and Acceptance Tests for a comprehensive list of submittal requirements and the 2021 Edition of the International Fire Code